

**ONS Station ALARA Committee Meeting 1<sup>st</sup> Quarter      March 22, 2022**

Sheila Dalton opened with TAM and confirmed quorum.

Phil Kelley facilitated meeting.

Minutes from 11/7/2021 were reviewed and accepted.

Bill Meldrum presented CRE data, Online exposure data for past 12 years, and the O2R30 dose update.

Bobby Leigh presented Group Online Dose. Groups above estimate as a result of forced outage and CRDMs.

Bill presented O3R31 Outage Estimate.

Bobby covered Dose Reduction Initiatives – SFP crane pendant, non-routine outage jobs, primary filter improvements (nuts). Bobby took an action to add owners for the SF Supp Cooling Mod.

Sheila asked if we should have an initiative to track savings from technology and innovations (i.e. Spot).

Meeting adjourned.

**ONS Station ALARA Committee Meeting Supplemental Meeting March 28, 2022**

Amanda Stevenson opened with TAM.

Sheila validated quorum.

Mike Eller presented 3B1 RCP Motor Replacement challenge. Paul Fisk questioned preparations regarding overall scope, piping cuts, shielding plans. Focus on 3D scans and models, hanger orientation, and historical dose comparisons. Plan was approved.

Mike Grams presented Alloy 600 Nozzle Repair challenge. Paul questioned Lessons Learned from U2 work and how they would be applied. Shielding, contingencies for discovery items, and Code Case approval for defects were discussed. Plan was approved.

Bill presented the O3R31 Outage Estimate, which was approved.

Action Item to Bobby to provide prior nozzle dam dose history.

Meeting adjourned.