

**VSDS Standard Map Survey Report
Oconee Nuclear Station**

Survey ONS-M-20210824-6

General Information

Survey Date/Time: 8/24/2021 07:00

Lead Surveyor: R. Leigh III

Survey Type: Job Coverage

Work Order/Task #:

Counted By: R. Leigh III 8/24/2021 08:00

RWP #: 2401

Rx % Pwr: 25%

Status: Ready for Review by: R. Leigh III, 8/24/2021

Dose Rate (DR) Object Prefixes/Suffixes

Dose Rates with Prefixes:

* = Contact

+ = 30cm

Dose Rates with No Prefixes:

Gen Area

Default Prefixes:

HS = Hot Spot

Default Suffixes:

"n" = Neutron

"b" = Beta

"c" = Corrected

Postings Legend

CA=Contaminated Area

LHRA=Locked High Radiation Area

RPBRFE=RP Brief Required For Entry

Instruments Used


#	Instrument Model	Instrument Serial #	Inst Type
1	Ludlum 9-3	12068	D
2	Ludlum 12-4	03142	D
3	APC	1	C
4	ALP	2	

VSDS Standard Map Survey Report Oconee Nuclear Station

Unit 2 Reactor Building Basement

Survey #: ONS-M-20210824-6

Date/Time: 8/24/2021 07:00



Unit 2 Reactor Building Basement

Comments: Entry into Unit 2 Basment @ 25% power to remove 2A1 Jleg drian insulation for Leak verification. No Leak discovered. Stay time and Dose rate alarms where adjusted to meet the field dose rate survey. Supervisoion notified.

Type: Job Coverage

Symbol Legend (for example only)	
Dose Rate	RWP #: 2401
*150 ← Contact Reading	Reactor Power = 25%
+75 ← 30 cm Reading	Tag Name: 25%power
20 ← General Area	
HS-50 Hot Spot	
RCA Posting	
Drip Bag	
15 Smear	15 Air Sample
15 RM	15 Wipe

Unless otherwise noted, dose rates in mrem/hr.

Lead Surveyor: R. Leigh III

Location Code: RB

Location Description: Unit 2 Reactor Building

Summary of Highest Readings (All available values may not be listed)

Smears	Air Samples & Wipes
1) 2K DPM/100 cm2 β/γ	
1) 2 DPM/100 cm2 α	

Status: Ready for Review by: R. Leigh III, 8/24/2021

Bldg/Area Name: U2 Reactor Building

**VSDS Standard Map Survey Report
Oconee Nuclear Station**

Data Point Details

Survey #: ONS-M-20210824-6

Map: 2RXBSMT

#	Type	Inst.	Value	Units	Position	Notes
DR	γ	N/A	0.5-2	mrem/hr		
DR	γ	N/A	100-200	mrem/hr		
DR	γ	N/A	200	mrem/hr		
DR	γ	N/A	40-50	mrem/hr		
DR	γ	N/A	150	mrem/hr		
DR	γ	N/A	500	mrem/hr		
DR	γ	N/A	* 4000 ----- + 3000 ----- 1400	mrem/hr mrem/hr mrem/hr	2A1 Jleg Drain	
DR	γ	N/A	100	mrem/hr		
DR	γ	N/A	50	mrem/hr		
DR	Neutron	N/A	30 η	mrem/hr		
DR	Neutron	N/A	3 η	mrem/hr		
DR	Neutron	N/A	4 η	mrem/hr		
1	Smear	N/A	β/γ 2K ----- α 2	DPM/100 cm2 DPM/100 cm2	Smear taken on boron covered floor	
2	Smear	N/A	β/γ <1000 ----- α 0	DPM/100 cm2 DPM/100 cm2	smear taken on boron covered floor	
3	Smear	N/A	β/γ <1000 ----- α 0	DPM/100 cm2 DPM/100 cm2	Smear taken on floor in walkpath to work area.	
	Posting		LHRA CA RPBRFE			
	Text		Entry @ 25% power			
	Text		2A1 JLeg Drian			
	Text		Leaking 2" Pipe 12' in overhead			