


HOT SPOT IDENTIFICATION RECORD

COMPONENT DEMOGRAPHIC INFORMATION

NOP-OP-4103-01 Rev. 00

Hot Spot #	Date Identified	Component type	Location	Building and Elevation
1-8	1-14-21	PIPING/VALVE	☒ Unit 1 ☐ Unit 2	722' PAB
Survey # 102175		Functional Location # Degasifier Cubicle 2A IBR-664		
Remarks / Description / Location Details:				
Located in opposite corner of ladder, approx. 1 ft. off the floor. Valve location IBR-664.				
RADIATION SURVEY DATA (mr/hr)		Picture / Photo (If available)		
Contact reading	210			
General Area Reading (30 cm or >)	8.5			
Instrument Model	Telepole			
Instrument ID #	6604-062			
Cal. Due	3/14/21			
Performed by (Print / Signature)		David V. Coradi: <i>DV Coradi</i>	Badge # 50129	Date: 1/15/21
Reviewed by (Print / Signature)		Sharon Williams: <i>Sharon Williams</i>	Badge# 13722	Date: 1-18-21